


NOTES

1. Cross-sidewalk pipes to be 2 x 3" cast iron pipes.
2. Min. 2" separation between drain pipes.
3. Drain box to be located on private property.
4. Concrete mix to include 1 lb. lampblack per cubic yard.
5. Install 6" x 6" welded wire mesh over pipes in sidewalk, if depth allows.

SCALE: NTS



CITY OF ALBANY, CALIFORNIA

STANDARD DETAIL

04-16-2019

**SIDEWALK DRAIN
RESIDENTIAL LOTS**

STD DETAIL No.
ST 14